

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1574:121 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004  
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

**DESIGN:** Model FSRZI-A remote zone indicator (Part No. 7990044), Model FSRSI remote system indicator (Part No. 7990043) and Model FSRRM remote relay module (Part No. 7990042). Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Primary Operating Supply: 21-25 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories for use with separately listed compatible fire alarm control units. For indoor use only.

**XLf:** 7300-1591:101

11-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 2, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager